
$\overline{\Box}$

Щ

 \vdash







- A ELECTRIC UTILITY SERVICE CONDUCTORS AND DEAD-END CONNECTOR (BY UTILITY). B HOUSE ATTACHMENT BRACKET (JOSLYN CAT. NO. J7692, OR EQUIVALENT)
- (2-HOLE ATTACHMENT BRACKET) PULL-OFF PLATE (C) WEATHERHEAD SUITABLE FOR RGS OR IMC SERVICE PIPE

RIGID GALVANIZED STEEL PIPE (OR IMC) AND CONDUCTORS

- [C] LEAVE A MINIMUM OF 12" CONDUCTOR TAIL FOR CITY SPLICING OF SERVICE
- 100 A 2-#3 PHASE AND 1-#3 NEUTRAL THWN COPPER CONDUCTORS IN 1-1/4 INCH PIPE (IDENTIFY NEUTRAL WITH WHITE TAPE) 200 A - 2-#3/0 PHASE AND 1-#3/0 NEUTRAL THWN COPPER CONDUCTORS IN 2 1/2 INCH PIPE (IDENTIFY NEUTRAL WITH WHITE TAPE) WHERE NECESSARY A SEPARATE STRUCTURAL SUPPORT IS TO BE PROVIDED AND FIRMLY ANCHORED TO BUILDING STRUCTURAL MEMBER THE USE OF COPPER CONDUCTORS IS PREFERRED FOR ALL SERVICE ENTRANCE INSTALLATIONS. HOWEVER, IF ALUMINUM CONDUCTORS ARE USED AS PART OF THE SERVICE ENTRANCE INSTALLATION, ALL CONNECTIONS, UP TO AND INCLUDING THE OF THE MAIN SERVICE ENTRANCE PANEL MUST BE MADE BY USE OF SCMEU-APPROVED
- (E) weatherproof threaded pipe connections (typical all external fittings)

ALUMINUM SERVICE ENTRANCE CONDUCTORS SHALL NOT BE PERMITTED.

COMPRESSION-TYPE CONNECTORS. THE USE OF MECHANICAL CONNECTORS ON


- (E) 2-HOLE CONDUIT STRAPS (TYPICAL EVERY 5 FEET)
- (F) THREADED METER SOCKET HUB CONNECTOR

H METER SOCKET (METER BY UTILITY)

- G INSULATED RIGID GALVANIZED STEEL BUSHING CONNECTOR
 - 200 A MILBANK CAT. NO. U7807RL200KK OVER 200 A - CONSULT UTILITY ENGINEERING DEPT. ADD FIFTH JAW FOR 120/208 V, 3-W SERVICE. METER SOCKET MUST BE SECURED TO BUILDING STRUCTURAL ELEMENT AND NOT JUST SIDING.
 - FOR SERVICES 400 A AND GREATER, EXTERNAL MAIN DISCONNECT/ DISCONNECTS ARE REQUIRED.
 - (I) 1/2" RIGID GALVANIZED STEEL PIPE (OR IMC) WITH #4 CU GROUND WIRE CONDUIT TO INCLUDE SUITABLE CONNECTOR AT END TO PREVENT GROUND WIRE FROM BEING PULLED OUT OF METER SOCKET. INSULATED GROUND CONDUCTOR TO BE CONTINUOUS TO MAIN PANEL NOT TO BE CONECTED AT METER SOCKET.
 - (J) GROUND ROD CONNECTOR (MUST BE VISIBLE)
 - (K) 5/8" X 8' COPPERWELD GROUND ROD
- (L) RIGID GALVANIZED STEEL PIPE (OR IMC) AND FITTINGS WITH CONDUCTORS 200 A - 2-#3/0 PHASE AND 1-#3/0 NEUTRAL THWN COPPER CONDUCTORS IN 2 INCH PIPE 100 A - 2-#3 PHASE AND 1-#3 NEUTRAL THWN COPPER CONDUCTORS IN 1-1/4 INCH PIPE
- M PANELBOARD WITH MAIN (100 A OR 200 A) CIRCUIT BREAKER (PANELBOARD TO BE LOCATED NO FURTHER THAN 5 FEET FROM METERING POINT WITHOUT AN EXTERNAL DISCONECT)
 - PANELBOARD TO BE SOLIDLY SECURED TO WALL AT TOP AND BOTTOM.


WHEN MOUNTED ON CONCRETE OR MASONRY WALLS, ON MINIMUM 1/2"

- THICK PLYWOOD SHALL BE MOUNTED BEHIND THE ELECRIC PANEL. PROVIDE MINIMUM OF 36" CLEAR WORKING SPACE IN FRONT OF PANELBOARD. (WIDTH OF CLEAR WORKING SPACE TO BE 36")
- 1/2" EMT CONDUIT WITH GROUND WIRE OR A BARE ARMORED GROUND 100 A - NO. 8 COPPER GROUND WIRE 200 A - NO. 4 COPPER GROUND WIRE
- 1/2' EMT CONDUIT END CONNECTOR SECURE CONDUCTOR TO CONDUIT
- P 1/2" CONDUIT STRAPS (TYPICAL)
- GROUND CONDUCTOR (AS SHOWN WITH JUMPER ACROSS WATER METER) 100 A - NO. 8 COPPER GROUND WIRE 200 A - NO. 4 COPPER GROUND WIRE
- (R) GROUND CONDUCTOR TO WATER LINE CONNECTOR
- S WATER METER
- INCOMING WATER LINE
- (U) NATURAL GAS METER A MINIMUM OF 10'-0" FROM SERVICE EQUIPMENT






- (2,) 4"x4" OR 6"x6" PRESERVATIVE TREATED WOOD POST.
- (3,) 2"x4" BLOCKING SOLIDLY INSTALLED BETWEEN RAFTERS.



- (1.) MOUNTING CLAMP WITH 1/2" BOLTS, NUTS AND WASHERS.
- (2) STEEL CONDUIT REDUCER.
- (3,) 2"x4" BLOCKING SOLIDLY INSTALLED BETWEEN RAFTERS.
- (4.) RIGID STEEL CONDUIT (2 1/2" FOR UP TO 200 AMPERES, 3" FOR LARGER SERVICE ENTRANCE EQUIPMENT. NOTE: USE OF IMC NOT PERMITTED FOR THIS APPLICATION.



NOTE: MINIMUM SERVICE SIZE FOR NEW ONE OR TWO FAMILY DWELLING IS 200 A. MINIMUM SERVICE SIZE FOR NEW MULTI FAMILY OR 3 OR MORE ATTACHED FAMILY IS 100 A.